

Furnizor: **Sc Trivolt Distribution SRL**
Reg. com.: J23/3300/2016
CIF: RO36421140
Adresa: Strada Apusului nr 3 (primul
sens giratoriu Tehodor Pallady-
Autostrada Soarelui), Catelu, Ilfov
Banca: BRD
IBAN: RO34BRDE441SV13182234410

ERSE CABLU RE-Y(ST)YSWAY-FL (MULTIPAIR) 4 X 2 X 1.5 , ERSE

Construc?ie

1. CONDUCTOR IEC-60228, VDE 0295, EN 60228
2. IZOLARE EN 50290-2-21 PVC combinate
3. Cod culoare BS-5308 PARTEA A-2 sau alb-negru;
Fiecare pereche numerotate
4. E?uare perechi, perechi, în straturi ?i
- 1 NUM?R COMUNICARE CORE
5. Placarea cu band? de PES
6. GENERAL SCREEN cupru cositorit DRAIN fir; TAPE AL-PES
7. INNER MANTAUA EN 50290-2-22 PVC combinate
8. Armour GALVANIZAT sârme de o?el ROTUNDE
9. MANTAUA EN 50290-2-22 PVC combinate
10. MANTAUA CULOARE RAL 5015 * BLUE; RAL 9005 * BLACK
cei care nu

Caracteristici tehnice

1. Rezisten?a conductorului (MAX) 0.50 mm² = 36 Ω / km
0,75 mm² = 24.5 Ω / km
1,0 mm² = 18.1 Ω / km
1.30 mm² = 13.9 Ω / km
1,5 mm² = 12.1 Ω / km
2. Rezisten?a de izola?ie (min) 100 MΩXKm
3. CAPACITATE MUTUAL (MAX) 0.50 mm² = 120 pF / m
0,75 mm² = 120 pF / m
1,0 mm² = 120 pF / m
1,3 mm² = 130 pF / m
1,5 mm² = 130 pF / m
4. Gam? de temperatur? - 30 ° C ~ +70 ° C (de stabilire a fixe)
5. FLACARA TEST IEC 60332-3-24; VDE 0482-266-2-4
RO 50266-2-4/BS EN 50266-2-4
6. L / R (raport) (MAX) 0.50 mm² = 25 mH / Ω
0,75 mm² = 25 mH / Ω
1,0 mm² = 25 mH / Ω
1.30 mm² = 40 mH / Ω
1.50 mm² = 40 mH / Ω
7. Curentul de sarcin? (25 ° C) 0.50 mm² = 6,0 A
0,75 mm² = 13 A
1,0 mm² = 16 A
1,30 mm² = 18 A
1,5 mm² = 20 A
8. Tensiunea de lucru 300/500 V.
9. TEST VOLTAJGE Core / Core = 2,000 V.
Core / Ecran = 2,000 V.
10. Indoire 10X cablu Ø
cerere

Pret: 0,00 lei (TVA inclus)

Detalii online: <https://www.materialelectrice.ro/cablu-re-y-st-ysway-fl-multipair-4-x-2-x-1-5-erse>

