

Furnizor: **Sc Trivolt Distribution SRL**
Reg. com.: J23/3300/2016
CIF: RO36421140
Adresa: Strada Apusului nr 3 (primul
sens giratoriu Tehodor Pallady-
Autostrada Soarelui), Catelu, Ilfov
Banca: BRD
IBAN: RO34BRDE441SV13182234410

	<u>ERSE CABLU RE-2Y(ST)Y- FL TIMF 16 X 3 X 1.3 , ERSE</u> Construc?ie 1. CONDUCTOR IEC-60228, VDE 0295, EN 60228 2. IZOLARE EN 50290-2-23 PE COMPONENTE 3. Cod culoare BS-5308 PARTEA-1 sau negru-alb ?i ro?u; 6. Placarea cu band? de PES 7. GENERAL SCREEN cupru cositorit DRAIN fir; TAPE AL-PES 8. MANTAUA EN 50290-2-22 PVC combinate 9. MANTAUA CULOARE RAL 5015 * BLUE; RAL 9005 * BLACK Caracteristici tehnice 1. Rezisten?a conductorului (MAX) 0.50 mm2 = 36 Ω / km 0,75 mm2 = 24.5 Ω / km 1,0 mm2 = 18.1 Ω / km 1.30 mm2 = 13.9 Ω / km 1,5 mm2 = 12.1 Ω ??/ km 2. REZISTEN?A NSULATION (MIN) 5000 MΩXKm 3. CAPACITATE MUTUAL (MAX) 0,50 mm2 = 100 pF / m 0,75 mm2 = 100 pF / m 1,0 mm2 = 100 pF / m 1,30 mm2 = 100 pF / m 1,5 mm2 = 100 pF / m 4. Gam? de temperatur? - 30 ° C ~ +70 ° C (de stabilire a fixe) 5. FLACARA TEST IEC 60332-3-24; VDE 0482-266-2-4 RO 50266-2-4/BS EN 50266-2-4 6. L / R (raport) (MAX) 0.50 mm2 = 25 mH / Ω 0,75 mm2 = 25 mH / Ω 1,0 mm2 = 25 mH / Ω 1.30 mm2 = 40 mH / Ω 1.50 mm2 = 40 mH / Ω 7. Curentul de sarcin? (25 ° C) 0.50 mm2 = 6,0 A 0,75 mm2 = 13 A 1,0 mm2 = 16 A 1,30 mm2 = 18 A 1,5 mm2 = 20 A 8. Tensiunea de lucru 300/500 V. 9. TEST VOLTAJGE Core / Core = 2,000 V. Core / Ecran = 2,000 V. 10. Raza de ?ndoire 7.5X cablu $\emptyset$ Pret: 0,00 lei (TVA inclus) Detalii online: https://www.materialeelectrice.ro/cablu-re-2y-st-y-fl-timf-16-x-3-x-1-3-erse
--	---